



Addendum

Addendum No. 2

Date: 9/17/2024

Project Number: 4415-01-16 (25)

Project: MEA HVAC Controls & Ventilation Upgrades
100 S. Warren St.
Helena, MT 59601

Bid Date: 9/24/2024

2:00 P.M. at HHA Conference Room, 812 Abbey St., Helena, MT 59601

Bidders for the above-captioned project are hereby informed that the drawings and/or specifications are modified, corrected or supplemented as follows. Acknowledge receipt of Addenda on Bid Form.

General Notes:

ITEM G-1 There are no testing and balancing requirements for this project. The mechanical engineer should be notified to assist in calibrating the first few bathroom exhaust fans.

ITEM G-2 The existing bathroom exhaust fan sizes are 8"x10". Not all apartment unit exhaust fans were verified.

END OF ADDENDUM

Crossman-Whitney-Griffin, Inc.


Matthew Avar, Project Architect

Attachments:

- N/A

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE DESIGNATED PLACE IN THE PROPOSAL FORM **AND ON THE FACE OF THE ENVELOPE.**

CWG
Architecture
+
Interiors

(406) 443-2340

650 Power St
P.O. Box 1198
Helena, MT 59624

cwg-architects.com